

# Gardner Fire Department Food Truck Compliance Checklist

Vehicle generally in good condition                      Yes                      No

Vehicle used for cooking                                      Yes                      No

Cooking appliance fuel: \_\_\_\_\_ N/A

Propane aggregate quantity: \_\_\_\_\_ N/A  
*Greater than 42 lbs. requires a permit (527 CMR 1.00 Sec. 69.1.2).*

Propane tank(s), lines inspected,  
compliant, in good condition                      Yes                      No                      N/A  
*Per 527 CMR 1.00 Sec. 69.3.12.*

Equipped with properly inspected hood                      Yes                      No                      N/A  
*Food trucks must comply with NFPA 96, Ventilation and Fire Protection of Commercial Cooking Operations, unless exempted by Gardner Fire Department (527 CMR 1.00 Sec. 50.2.1.9).*

Fire extinguisher(s) present, appropriate                      Yes                      No  
*Portable fire extinguishers shall be installed in kitchen cooking areas and shall be specifically listed for such use (NFPA 96 10.10.1 and 527 CMR 1.00 Sec. 69.3.12.8).  
A minimum of one extinguisher (at least 2-A:10-B:C) for internal combustion generator (527 CMR 1.00 Sec. 10.15.10.4)*

Generator compliant, safe practice,  
no additional stored gasoline containers                      Yes                      No                      N/A  
*Fuel tanks adequate to permit uninterrupted operation during operating hours (527 CMR 1.00 Sec. 10.15.10.1).*

Egress from vehicle maintained                                      Yes                      No  
*Appliances shall be located so that a fire at any appliance will not block egress of persons from the vehicle (527 CMR 1.00 Sec. 69.3.12.7.9).*

Proper separation distances for vehicle                      Yes                      No                      N/A  
*Concession stands utilized for cooking shall have a minimum of 10 ft. on two sides (527 CMR 1.00 Sec. 10.15.8).*

Business Name: \_\_\_\_\_

Representative Name: \_\_\_\_\_

Phone Number: \_\_\_\_\_ Email Address: \_\_\_\_\_

Inspected by: \_\_\_\_\_

Date: \_\_\_\_\_

Time: \_\_\_\_\_

The Gardner Fire Department inspector may order that this vehicle not operate within the city if any of the above items are found to be unsatisfactory.